



# Certificate of Compliance

This certificate is issued for the following:

## Pipe Hanger Components for Automatic Sprinkler Systems

<i>Product Designation</i>	<i>Hanger Rod Size, mm</i>	<i>Component Description</i>	<i>For Nominal Pipe Sizes, in.</i>	<i>Remarks</i>
EM10	M10	Drop-in Anchor	3/4 through 4	a, b
EM12	M12	Drop-in Anchor	5, 6, 8	a, b
EM16	M16	Drop-in Anchor	10, 12	a, b
EM20	M20	Drop-in Anchor	10, 12	a, b

### Remarks

- a. These expansion shields are available in zinc plated carbon steel and 316 stainless steel.
- b. These anchors are also FM Approved when threaded for use with the nearest equivalent Standard UNC size rod.

### Prepared for:

MKT- Metall- Kunststoff- Technik GmbH & Co KG  
Auf Dem Immel 2  
D-067685 Weilerbach  
Germany

FM Approvals Class: 1952

Approval Identification: 0003002567

Approval Granted: June 21, 1999

To verify the product continues to be Approved please refer to [www.approvalguide.com](http://www.approvalguide.com).

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads "David B. Fuller". The signature is written in a cursive style.

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062 USA

February 16, 2018

Date



Member of the FM Global Group